

April 8, 2021

Jarrod Parasmo President Protech Medical 1360 North Killian Drive, Suite 2 Lake Park, Florida 33403

Dear Jarrod:

Enclosed are the attenuation and lead equivalency results for the core materials that were submitted to Health Physics Northwest. At your request these tests were performed in accordance with ASTM test Method F2547-18. The documentation on the following pages contains all of the information regarding this testing.

If you have any questions, please contact our office.

Sincerely,

Matt Brien, BS Medical Physicist

Matt Bren

Encl.

ASTM test Method F2547-18 14.2.1 Test Information

Date of Testing
Place of Testing
Name of Individual Performing the Testing
Manufacturer and Model of X-ray
Generator

Manufacturer / Model of X-ray Tube

March 17, 2021
Health Physics Northwest
Matt Brien, BS Health Physics Northwest
Trex TM50 (G-9750A)

Varex Imaging Corporation / A-192

Set kVp Measured kVp mAs Half-Value Layer (mmAl)

Testing Parameters			
80	100		
79.9	100.3		
80	60		
4.01	5.22		

All exposure and kVp measurements performed with an Unfors RaySafe X2 R/F sensor, Serial No.: 245885 calibrated August 24, 2020.

			Atten	uation
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Bilayer	2	0.25	91.7%	85.3%
(0.25 mm LE)	4	0.50	98.0%	94.9%

		Lead Equivalency (mm Pb)		
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Bilayer	2	0.25	0.26	0.26
(0.25 mm LE)	4	0.50	0.52	0.51



		Atten	uation	
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
	2	0.25	90.5%	84.6%
Premier (0.125 mm LE)	3	0.375	95.6%	91.8%
(0.120 11111 EL)	4	0.50	97.8%	95.3%

			Lead Equivale	ency (mm Pb)
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
	2	0.25	0.24	0.25
Premier (0.125 mm LE)	3	0.375	0.37	0.38
	4	0.50	0.51	0.53



			Atten	uation
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Premier	2	0.35	94.5%	90.3%
(0.167 mm LE)	3	0.525	98.0%	95.6%

			Lead Equivale	ency (mm Pb)
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Premier	2	0.35	0.33	0.34
(0.167 mm LE)	3	0.525	0.52	0.54



		Atten	uation	
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
	1	0.125	77.3%	68.9%
Prolite Lead-	2	0.25	91.9%	85.6%
Free (0.125 mm LE)	3	0.375	96.4%	92.1%
	4	0.50	98.3%	95.4%

			Lead Equivale	ency (mm Pb)
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Prolite Lead- Free (0.125 mm LE)	1	0.125	0.12	0.12
	2	0.25	0.27	0.26
	3	0.375	0.40	0.39
	4	0.50	0.56	0.53



		Atteni	uation	
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Prolite Lead-	2	0.35	95.4%	90.6%
Free (0.167 mm LE)	3	0.50	98.3%	95.4%

			Lead Equivale	ency (mm Pb)
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Prolite Lead-	2	0.35	0.36	0.35
Free (0.167 mm LE)	3	0.525	0.56	0.53



		Atten	uation	
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
	2	0.25	91.8%	85.6%
Ultralite (0.125 mm LE)	3	0.375	96.3%	92.2%
(0.120 11111 22)	4	0.50	98.1%	95.4%

			Lead Equivalency (mm Pb)	
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Ultralite (0.125 mm LE)	2	0.25	0.26	0.26
	3	0.375	0.40	0.39
	4	0.50	0.53	0.53



			Attenuation	
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Ultralite (0.167 mm LE)	2	0.35	95.2%	90.3%
	3	0.525	98.1%	95.4%

			Lead Equivalency (mm Pb)	
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Ultralite (0.167 mm LE)	2	0.35	0.35	0.35
	3	0.525	0.54	0.53



			Attenuation	
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Light Lead (0.125 mm LE)	2	0.25	91.6%	85.4%
	3	0.35	95.9%	91.7%
	4	0.50	97.8%	95.0%

			Lead Equivalency (mm Pb)	
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Light Lead (0.125 mm LE)	2	0.25	0.26	0.26
	3	0.35	0.38	0.38
	4	0.50	0.51	0.51



			Attenuation	
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Standard Lead (0.25 mm LE)	1	0.25	90.8%	84.4%
	2	0.50	97.6%	94.7%

			Lead Equivalency (mm Pb)	
Product	Number of Layers	Reported LE (mm)	80 kVp	100 kVp
Standard Lead (0.25 mm LE)	1	0.25	0.24	0.25
	2	0.50	0.49	0.49

